

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20140212-EX15384  
**Report Reference** EX15384-20090827  
**Issue Date** 2014-FEBRUARY-12

**Issued to:** Y S VALVE MFG CO LTD  
30 TOU LUNG LI  
LUKANG  
CHANGHUA  
505 TAIWAN


**This is to certify that representative samples of** BUTTERFLY VALVES  
“See Addendum Page”

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL 1091 - Standard for Butterfly Valves for Fire Protection Service  
UL 38 - Standard for Manual Signaling Boxes for Fire Alarm Systems  
UL 753 - Standard for Alarm Accessories for Automatic Water-Supply Control Valves for Fire Protection Service  
ULC/ORD C1091 - Preliminary Standard for Butterfly Valves for Fire Protection Service  
CAN/ULC S548 - Devices and Accessories for Water Type Extinguishing Systems

**Additional Information:** See the UL Online Certifications Directory at [www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with “C” and “US” identifiers:  the word “LISTED”; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20140212-EX15384  
**Report Reference** EX15384-20090827  
**Issue Date** 2014-FEBRUARY-12

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

The butterfly valves are intended for use as water supply control valves for fire protection systems in above ground applications in the following models, sizes, end configurations and pressure ratings:

Listing	Model	NPS	Body Material	End Configuration	Rated Pressure, psig	Operator Model
USL	YS-2811A	1	Bronze or Brass	Threaded	300	7201
USL, CNL	YS-2811A	1-1/4, 1-1/2, 2, 2-1/2	Bronze or Brass	Threaded	300	7201
USL, CNL	YS-2812A	1-1/4, 1-1/2, 2, 2-1/2	Bronze or Brass	Grooved	300	7201

The Models YS-2811A and YS-2812A butterfly valves are intended for above ground installations only. The gear operator outlined above may be factory fitted with pre-wired or field wired internal supervisory tamper switches which have been qualified for indoor and outdoor use.

The Model YS-2812A butterfly valve incorporates the same construction as the YS-2811A, except for the end configuration.



William R. Carney, Director, North American Certification Programs  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)

