

CERTIFICATE OF COMPLIANCE

Certificate Number 20141222-EX26524
Report Reference EX26524-20141219
Issue Date 2014-DECEMBER-22

Issued to: Juntong Machinery Auxiliaries Co Ltd

**This is to certify that
representative samples of**

FITTINGS, RUBBER GASKETED
See Addendum Page

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL 213, Rubber Gasketed Fittings for Fire-Protection
Service
ULC/ORD 213, Rubber Gasketed Fittings for Fire-
Protection Service

Additional Information:

See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.

This is to certify that representative samples of the product as specified on this certificate were tested
according to the current UL requirements.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20141222-EX26524
Report Reference EX26524-20141219
Issue Date 2014-DECEMBER-22

Coupling


| Model | Groove Type | Pipe | Size (in.) | Rated Pressure (psig) |
|-------|-------------|----------|---|-----------------------|
| XGQT1 | Rolled | 10 | 1, 1-1/4, 1-1/2, 2, 3, 4, 6 | 300 |
| XGQT1 | Rolled | 10 | 8, 10 | 232 |
| XGQT1 | Rolled, Cut | 40 | 1, 1-1/4, 1-1/2, 2, 3, 4, 6 | 300 |
| XGQT1 | Rolled, Cut | 40 | 8, 10 | 232 |
| XGQT1 | Cut, Rolled | GB/T3091 | 3OD(76.1mm), 4-1/4OD(108.1mm), 5-1/4OD(133mm), 5-1/2OD(139.7mm), 6-1/4OD(159mm), 6-1/2OD(165.1mm) | 300 |

Flexible coupling

| Model | Groove Type | Pipe | Size (in.) | Rated Pressure (psig) |
|-------|-------------|----------|-------------------------------------|-----------------------|
| XGQT2 | Rolled | 10 | 4 | 300 |
| XGQT2 | Rolled | 10 | 8 | 232 |
| XGQT2 | Rolled, Cut | 40 | 4 | 300 |
| XGQT2 | Rolled, Cut | 40 | 8 | 232 |
| XGQT2 | Cut, Rolled | GB/T3091 | 5-1/2OD(139.7mm) , 6-1/2OD(165.1mm) | 300 |

Flange Adapter

| Model | Groove Type | Pipe | Size (in.) | Rated Pressure (psig) |
|--------|-------------|------|----------------|-----------------------|
| XGQT18 | Rolled | 10 | 2, 3, 4, 6, 8; | 232 |



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20141222-EX26524
Report Reference EX26524-20141219
Issue Date 2014-DECEMBER-22

| | | | | |
|--------|-------------|----------|--|-----|
| XGQT18 | Rolled, Cut | 40 | 2, 3, 4, 6, 8; | 232 |
| XGQT18 | Cut, Rolled | GB/T3091 | 3OD(76.1mm), 4-1/4OD(108.1mm), 5-1/4OD(133mm), 5-1/2OD(139.7mm), 6-1/4OD(159mm), 6-1/2OD(165.1mm); | 232 |

Side Outlet/ Mechanical Tee (for use with grooved end pipe or this manufacturer's grooved end fittings)

| Model | Groove Type | Pipe | Size (in.) | Rated Pressure (psig) |
|--------|-------------|----------|--|-----------------------|
| XGQT3 | Grooved | 10, 40 | 2 x 1, 1-1/4, 1-1/2; 3 x 1, 1-1/4, 1-1/2, 2; 4 x 1, 1-1/4, 1-1/2, 2, 3OD(76.1mm); 6 x 1, 1-1/4, 1-1/2, 2, 3OD(76.1mm), 3, 4; | 300 |
| XGQT3 | Grooved | 10, 40 | 8 x 1, 1-1/4, 1-1/2, 2, 3OD(76.1mm), 3, 4-1/4OD(108.1mm), 4; | 232 |
| XGQT3 | Grooved | GB/T3091 | 3OD(76.1mm) x 1, 1-1/4, 1-1/2; 4-1/4OD(108.1mm) x 1, 1-1/4, 1-1/2, 2, 3OD(76.1mm); 5-1/2OD(139.7mm) x 1, 1-1/4, 1-1/2, 2, 3OD (76.1mm), 3; 6-1/2OD(165.1mm) x 1, 1-1/4, 1-1/2, 2, 3OD(76.1mm), 3, 4; | 300 |
| XGQT3S | Threaded | 10, 40 | 2 x 1, 1-1/4, 1-1/2; 3 x 1, 1-1/4, 1-1/2, 2; 4 x 1, 1-1/4, 1-1/2, 2, 3OD(76.1mm); 6 x 1, 1-1/4, 1-1/2, 2, 3OD(76.1mm), 3; | 300 |
| XGQT3S | Threaded | 10,40 | 8 x 1, 1-1/4, 1-1/2, 2, 3OD(76.1mm), 3, 4; | 232 |
| XGQT3S | Threaded | GB/T3091 | 3OD(76.1mm) x 1, 1-1/4, 1-1/2; 4-1/4OD(108.1 mm) x 1, 1-1/4, 1-1/2, 2, 3OD(76.1mm); 5-1/2OD(139.7mm) x 1, 1-1/4, 1-1/2, 2, 3OD (76.1mm), 3; 6-1/4OD(159 mm) x 1, 1-1/4, 1-1/2, 2, 3OD (76.1mm), 3; 6-1/2OD(165.1mm) x 1, 1-1/4, 1-1/2, 2, 3OD(76.1mm), 3, 4; | 300 |
| XGQT3U | | 10, 40 | 1 x 1/2, 3/4; 1-1/4 x 1/2, 3/4, 1; 1-1/2 x 1/2, 3/4, 1; | 300 |

B. Mahrenholz

Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC


Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20141222-EX26524
Report Reference EX26524-20141219
Issue Date 2014-DECEMBER-22

| | | | | |
|--------|--|----------|---------------------------|-----|
| | | | 2 x 1/2, 3/4, 1; | |
| XGQT3U | | GB/T3091 | 3OD(76.1mm)x 1/2, 3/4, 1; | 300 |



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

