

Certificate of Approval

This certificate confirms that the company below complies with the following standard(s):

Company Name	Ningbo Kaixuan Fire Control Equipment Co.,Ltd.	Client ID	104630
Company Other Name		Type of Certification	Product Certification; System 1
Certification Standard	NEN 3374-1971 : Fire Fighting Equipment – Fire hose couplings and Ancillary Equipment		
Scheme	Global-Mark Product Conformance Scheme		
Certification Review Date	27/10/2019	Certification Expiry Date	27/10/2022
Certificate Issue Date	27/10/2019	Certificate Last Update Date	31/10/2019


APPROVED COMPANY/SITE ADDRESS(ES):

No. 999 Zhonghe Road Huangjiabu Town Yuyao City Zhejiang - China

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Approval remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager



Unique Certificate Code: **2F2E20463310948FCA2584A100029927**

Global-Mark Pty Ltd, 407, 32 Delhi Road, North Ryde NSW 2113, Australia - Copyright 2005



Global-Mark.com.au®





Model(s) on which the Global-Mark logo may be applied by the certificate holder as a declaration of compliance by the certificate holder:

In placing the authorised mark on the product, the certificate holder makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein. In issuing this Certificate of Approval Global-Mark has relied on the expertise of external bodies (laboratories, and technical experts).

Model Identification	Model Name	Brand Name	Product Description/Attributes	Date Approved
KX08-020A-00	Storz adaptor	Jingtian	Storz Adaptor – Female thread (BSP), 2 1/2" (65mm), Working pressure: 16 Bar, Material: Forged AlMgSi Alloy	19/10/2019
KX08-020B-00	Storz adaptor	Jingtian	Storz Adaptor – Female thread, IDØ77 x 5 1/5 TPI (65mm), Working pressure: 16 Bar, Material: Forged AlMgSi Alloy	19/10/2019
KX08-020C-00	Storz adaptor	Jingtian	Storz Adaptor – Female thread (SART), 2 1/2" (65mm), Working pressure: 16 Bar, Material: Forged AlMgSi Alloy	19/10/2019
KX08-020D-00	Storz adaptor	Jingtian	Storz Adaptor – Female thread (QRT), 2 1/2" (65mm), Working pressure: 16 Bar, Material: Forged AlMgSi Alloy	19/10/2019
KX08-020E-00	Storz adaptor	Jingtian	Storz Adaptor – Female thread (CFA), 63x8.47, Working pressure: 16 Bar, Material: Forged AlMgSi Alloy	19/10/2019
KX08-020F-00	Storz adaptor	Jingtian	Storz Adaptor – Male thread (BSP), 2 1/2" (65mm), Working pressure: 16 Bar, Material: Forged AlMgSi Alloy	19/10/2019
KX08-020G-00	Storz adaptor	Jingtian	Storz Adaptor – Male thread (NSW), 2 1/2" (65mm), Working pressure: 16 Bar, Material: Forged AlMgSi Alloy	19/10/2019
KX08-020H-00	Storz adaptor	Jingtian	Storz Adaptor – Male thread (SART), 2 1/2" (65mm), Working pressure: 16 Bar, Material: Forged AlMgSi Alloy	19/10/2019
KX08-020J-00	Storz adaptor	Jingtian	Storz Adaptor – Male thread (QRT), 2 1/2" (65mm), Working pressure: 16 Bar, Material: Forged AlMgSi Alloy	19/10/2019
KX08-020K-00	Storz adaptor	Jingtian	Storz Adaptor – Male thread (CFA), 63x8.47 (65mm), Working pressure: 16 Bar, Material: Forged AlMgSi Alloy	19/10/2019

Comments:

Corrected typo errors.

End of the document



Certification Manager